



## Legislation Details (With Text)

---

**File #:** 52420      **Version:** 1      **Name:** 202-204-206 State St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 7/11/2018      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 7/17/2018  
**Enactment date:**      **Enactment #:**  
**Title:** 202-204-206 State St C-07-61-2018  
Amy Hasselman of Kontext Architects, LLC appealing IBC 1028.1. The exit discharge shall not reenter a building. The rear exits of 202-204-206 State St pass under the parking ramp. This configuration was approved on May 16, 2006 by the Building Board of Appeals. The new plan is a change of use. Alder District 4  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. State St 202 application.pdf

Date	Ver.	Action By	Action	Result
7/17/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

### Title

202-204-206 State St C-07-61-2018

Amy Hasselman of Kontext Architects, LLC appealing IBC 1028.1. The exit discharge shall not reenter a building. The rear exits of 202-204-206 State St pass under the parking ramp. This configuration was approved on May 16, 2006 by the Building Board of Appeals. The new plan is a change of use. Alder District 4