



Legislation Details

File #: 52448 **Version:** 1 **Name:** 215 Martin Luther King Jr. Blvd
Type: Miscellaneous **Status:** Petition for Variance, Exception, or Appeal
File created: 7/13/2018 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/7/2022
Enactment date: **Enactment #:**
Title: 215 Martin Luther King Jr. Blvd C-07-60-2018
Randall Jacobs of MEP Associates, LLC appealing IMC section 607.3.3.2.1. The rule requires that a smoke detector be installed within five feet of a damper. There are two different situations. The Madison Fire Department supports the variance for a distance greater than 5 feet.
Alder District 4
Sponsors:
Indexes:
Code sections:
Attachments: 1. refund request.pdf

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------