



## Legislation Details

**File #:** 52837      **Version:** 1      **Name:** 4101 Lien Rd  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 8/14/2018      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 9/18/2018  
**Enactment date:**      **Enactment #:**  
**Title:** 4101 Lien Rd C-08-66-2018  
Roger Schregardus of Boldt Technical Services appealing IBC Table 506.2.  
1-story building fully sprinklered system, IIB construction type F1 occupancy classification. Table 506.2 states maximum allowable area allowed is 62,000 sqft. The Madison Fire Department supports the variance to be 11% over allowable area.  
Alder District 17

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 4101 Lien Rd - BBA application.pdf, 2. 4101 Lien Rd revised materials.pdf

Date	Ver.	Action By	Action	Result
9/18/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	
8/21/2018	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	