



Legislation Details

File #: 54643 **Version:** 1 **Name:** 4101 Lien Rd
Type: Miscellaneous **Status:** Approved
File created: 2/7/2019 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/20/2019
Enactment date: **Enactment #:**
Title: 4101 Lien Rd.
BLDNCC-2018-14504
Roger Schregardus of Boldt Technical Services is seeking a variance to allow a 12" landing instead of the 44" landing as required under IBC 1010.1.6. The doors in question are Fire Department Access doors to high-piled storage per IFC 3206.6.1. The Fire Department Supports the variance.
Alder District 17

Sponsors:

Indexes:

Code sections:

Attachments: 1. 4101 Lien Rd Petition for Variance Application.pdf

Date	Ver.	Action By	Action	Result
2/20/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	