



Legislation Details

File #: 54746 **Version:** 1 **Name:** 308 S Paterson St
Type: Miscellaneous **Status:** Approved
File created: 2/15/2019 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/20/2019
Enactment date: **Enactment #:**
Title: 308 S. Paterson St
BLDNCC-2018-02241
James McFadden is seeking a variance to allow the ceiling height in the basement to remain 6' with 5' 5.5" clearance under the beams. IBC 1003.2 requires 7' 6" minimum ceiling height. The space is not normally occupied and will have a cooler and some storage. The Madison Fire Department has conditionally approved the variance. Alder District 6
Sponsors:
Indexes:
Code sections:
Attachments: 1. 308_S_Paterson.pdf

Date	Ver.	Action By	Action	Result
2/20/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	