



Legislation Details (With Text)

| | | | | | |
|------------------------|--|----------------------|---|----------------------|--|
| File #: | 55337 | Version: | 1 | Name: | 1000 Edgewood College Drive |
| Type: | Miscellaneous | Status: | | Status: | Held in Committee |
| File created: | 4/8/2019 | In control: | | In control: | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD |
| On agenda: | | Final action: | | Final action: | 3/31/2022 |
| Enactment date: | | Enactment #: | | | |
| Title: | 1000 Edgewood College Dr. BLDNCC-2013-06890 Michael Guns of Edgewood College is seeking a variance to request a special locking system for after hours for safety issues, such as an active shooter, appealing IBC 1010.1.9, which requires all exit doors to open from the egress side at all times. The City of Madison Fire Department has conditionally approved the variance. Alder District #13 | | | | |
| Sponsors: | | | | | |
| Indexes: | | | | | |
| Code sections: | | | | | |
| Attachments: | 1. 1000_edgewood_college_dr_bba.pdf | | | | |

| Date | Ver. | Action By | Action | Result |
|-----------|------|---|--------|--------|
| 5/21/2019 | 1 | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD | Table | |

Title

1000 Edgewood College Dr.
BLDNCC-2013-06890
Michael Guns of Edgewood College is seeking a variance to request a special locking system for after hours for safety issues, such as an active shooter, appealing IBC 1010.1.9, which requires all exit doors to open from the egress side at all times. The City of Madison Fire Department has conditionally approved the variance.
Alder District #13