



Legislation Details

File #:	55884	Version:	1	Name:	308 N. Carroll St.
Type:	Miscellaneous	Status:	Withdrawn		
File created:	6/13/2019	In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD		
On agenda:		Final action:	6/18/2019		
Enactment date:		Enactment #:			
Title:	308 N. Carroll St. BLDVAR-2019-07150 Scott Pratt of Live Here, LLC is seeking a variance from IBC 1011.10 to allow a spiral stair to be used as an exit for space of 900 sp. ft. and 8 occupants. The proposed stair was previously considered with no action taken by the Building Board of Appeals. Design alterations have been made to the stairway to meet the code requirements except for the required 7.5" tread depth at a point 12" from the narrow edge. Alder District #4				
Sponsors:					
Indexes:					
Code sections:					
Attachments:	1. 308 N Carroll - Application.pdf, 2. 308 N Carroll - Supplementary Information.pdf				

Date	Ver.	Action By	Action	Result
6/18/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Withdrawn by Applicant	
5/21/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	