



## Legislation Details

**File #:** 55898      **Version:** 1      **Name:** 1513 Parkside Dr.  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 5/10/2019      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 5/21/2019  
**Enactment date:**      **Enactment #:**  
**Title:** 1513 Parkside Dr.  
Brendan Kress of Strand Associates, Inc. is seeking a variance to exit through an adjacent tenant space. IBC 1016.2.1 prohibits exiting through adjacent tenant space. The City of Madison Fire Department supports this variance with the condition the future renovations shall attempt to streamline the exiting; the exit signs and emergency lighting shall comply with the 2015 IBC.  
Alder District #17  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 1513\_parkside\_dr\_bba.pdf

Date	Ver.	Action By	Action	Result
5/21/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	