



Legislation Details (With Text)

File #: 56556 **Version:** 1 **Name:** Request from City Engineering to Repair the Outfall at Spring Harbor Boat Launch

Type: Communication **Status:** Approved

File created: 7/1/2019 **In control:** BOARD OF PARK COMMISSIONERS

On agenda: **Final action:** 7/10/2019

Enactment date: **Enactment #:**

Title: Request from City Engineering to Repair the Outfall at Spring Harbor Boat Launch

Sponsors:

Indexes:

Code sections:

Attachments: 1. Spring Harbor Outfall.pdf, 2. Spring Harbor Outfall Presentation.pdf

Date	Ver.	Action By	Action	Result
7/10/2019	1	BOARD OF PARK COMMISSIONERS	Approve	Pass

Title

Request from City Engineering to Repair the Outfall at Spring Harbor Boat Launch

Body

The August 20, 2018 rain event caused excessive scour beneath a concrete retaining wall adjacent to the storm sewer outfall at Spring Harbor. The scour caused the wall to rotate and, ultimately, fail. A temporary sheetpiling wall was installed to stabilize the bank until a permanent repair could be designed.

The proposed project will install a permanent repair for the failed retaining wall. The proposed wall replacement will likely damage a portion of the boat launch pavement, which is aged and somewhat degraded. Therefore, the project will also replace the existing boat launch pavement and curb stops with new asphalt and concrete curb and gutter.