



Legislation Details (With Text)

File #: 61204 **Version:** 1 **Name:** 216 S Pinckney St
Type: Miscellaneous **Status:** Approved
File created: 7/2/2020 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 7/6/2020
Enactment date: **Enactment #:**

Title: 216 S Pinckney St
BLDVAR-2020-08426
The applicant is seeking a variance from 2015 IBC 1006.2.1 requiring two exits or exit access doorways from any space in a R-2 occupancy with an occupant load exceeding the allowable limit of 10 individuals. Specifically, the applicant is seeking permission to increase the allowable occupant load to 20 individuals for a single exit pathway. Alder District #4.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2015 Code.pdf, 2. 2018 Code.pdf, 3. application_0001.pdf, 4. ICC email_0001.pdf, 5. JDS floor plans.pdf, 6. Pinckney St 216 S IBC 1006 MFD Position 7-3-2020.pdf, 7. Code Change E17-15 Table 1006.2.1.pdf, 8. PublicComment-RegistrantsReport.pdf

Date	Ver.	Action By	Action	Result
7/6/2020	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

216 S Pinckney St
BLDVAR-2020-08426

The applicant is seeking a variance from 2015 IBC 1006.2.1 requiring two exits or exit access doorways from any space in a R-2 occupancy with an occupant load exceeding the allowable limit of 10 individuals. Specifically, the applicant is seeking permission to increase the allowable occupant load to 20 individuals for a single exit pathway. Alder District #4.