



## Legislation Details (With Text)

**File #:** 61378 **Version:** 1 **Name:** 9604 Wilrich St  
**Type:** Miscellaneous **Status:** Approved  
**File created:** 7/14/2020 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:** **Final action:** 7/21/2020  
**Enactment date:** **Enactment #:**

**Title:** 9604 Wilrich St  
BLDVAR-2020-09024  
The applicant is seeking a variance from 2015 IBC 1006.2.1 requiring two exits or exit access doorways from any space in a R-2 occupancy with an occupant load exceeding the allowable limit of 10 individuals. The applicant is seeking permission to increase the allowable occupant load to 15 individuals for a single exit pathway. Alder District #9.

### Sponsors:

### Indexes:

### Code sections:

**Attachments:** 1. 9604 wilrich variance.pdf, 2. Wilrich St 9604 IBC 1006 MFD Position 7-13-2020.pdf, 3. 7-21-2020\_PublicComment-RegistrantsReport.pdf

Date	Ver.	Action By	Action	Result
7/21/2020	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

### Title

9604 Wilrich St  
BLDVAR-2020-09024

The applicant is seeking a variance from 2015 IBC 1006.2.1 requiring two exits or exit access doorways from any space in a R-2 occupancy with an occupant load exceeding the allowable limit of 10 individuals. The applicant is seeking permission to increase the allowable occupant load to 15 individuals for a single exit pathway. Alder District #9.