



Legislation Details (With Text)

File #:	62197	Version:	1	Name:	650 Forward Dr
Type:	Miscellaneous	Status:		Status:	Approved
File created:	9/10/2020	In control:		In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:		Final action:	9/22/2020
Enactment date:		Enactment #:			

Title: 650 Forward Dr.
BLDVAR-2020-10975
The applicant is seeking a variance from 2015 IBC 507.5 requiring Group B, F, M, or S buildings that are no more than two stories above the grade plane, equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, and unlimited in area, to be surrounded and adjoined by public ways or yards not less than 60 feet in width. The proposed project contains an enclosed pedestrian walkway infringing upon the required 60 foot public way or yard space surrounding the building. Alder District #19.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 650 forward dr 1.pdf, 2. 650 forward dr 2.pdf, 3. 650 Forward Dr 3.pdf, 4. 650 forward var.pdf, 5. FinalPublicComment-RegistrantsReport.pdf

Date	Ver.	Action By	Action	Result
9/22/2020	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

650 Forward Dr.
BLDVAR-2020-10975

The applicant is seeking a variance from 2015 IBC 507.5 requiring Group B, F, M, or S buildings that are no more than two stories above the grade plane, equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, and unlimited in area, to be surrounded and adjoined by public ways or yards not less than 60 feet in width. The proposed project contains an enclosed pedestrian walkway infringing upon the required 60 foot public way or yard space surrounding the building. Alder District #19.