



Legislation Details

File #: 64663 **Version:** 1 **Name:** 825 Williamson St
Type: Miscellaneous **Status:** Approved
File created: 3/11/2021 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/16/2021
Enactment date: **Enactment #:**

Title: 825 Williamson St
BLDVAR-2021-02928
The property owner is seeking a variance from IBC Table 602 requiring a 1 hour fire resistance rating for the exterior wall of a Occupancy Group B, Type VB building located less than 10 feet from the property line. The property owner is also seeking a variance from 2015 IBC Table 705.8 that does not permit exterior wall openings for fire resistive walls located less than 3 feet from the property line. The existing building is a single family home and is being converted to a commercial office, the building is located 2.5 feet from the property line and the exterior wall needing fire resistive rating has 5 window openings. Alder District 6.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 1.4.21 SET.pdf, 2. 817-821 Williamson ST.pdf, 3. Front Elevation 825 Williamson.pdf, 4. Signed - West Wall Variance Applciation.pdf, 5. West Elevation 825 Williamson.pdf, 6. Williamson St 825 IBC 602 MFD Position 2-24-2021.pdf

Date	Ver.	Action By	Action	Result
3/16/2021	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass