



## Legislation Details

<b>File #:</b>	65518	<b>Version:</b>	1	<b>Name:</b>	526 Stone Arbor Trl
<b>Type:</b>	Miscellaneous	<b>Status:</b>		<b>Status:</b>	Approved
<b>File created:</b>	5/12/2021	<b>In control:</b>		<b>In control:</b>	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
<b>On agenda:</b>		<b>Final action:</b>		<b>Final action:</b>	5/18/2021
<b>Enactment date:</b>		<b>Enactment #:</b>			
<b>Title:</b>	526 Stone Arbor Trl BLDVAR-2021-06575 The prospective property owner is seeking a variance to SPS 321.07(b) requiring exit doors be openable from the interior without the use of a key. The prospective property owner is proposing the installation of a magnetic locking system within the home to provide support for a resident with special health and safety needs and prohibit the resident from leaving without supervision. Alder District 9.				
<b>Sponsors:</b>					
<b>Indexes:</b>					
<b>Code sections:</b>					
<b>Attachments:</b>	1. 526 stone arbor variance application.pdf, 2. 526 Stone Arbor MFD position 5-14-2021.pdf, 3. Maglock Document.pdf				

Date	Ver.	Action By	Action	Result
5/18/2021	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass