



Legislation Details

File #:	66357	Version:	1	Name:	
Type:	Miscellaneous	Status:		Status:	Approved
File created:	7/8/2021	In control:		In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:		Final action:	8/11/2021
Enactment date:		Enactment #:		Enactment #:	

Title: 2222 E Washington Ave
BLDVAR-2021-10276
Seeking a variance from 2015 IBC 1017.2 limiting group E buildings to a maximum exit travel distance of 200 feet in non-sprinklered buildings or 250 feet in buildings with sprinkler systems. The property owner is proposing the removal of an interior stairwell in combination with the installation of a full sprinkler system which will result in the reduction of a non-conforming exit travel distance from about 80 feet to 76 feet over the allowable exit travel distance. Alder District 12.

Sponsors:

Indexes:

Code sections:

Attachments: 1. MMSD 3- 2222 E Wash stairs.pdf, 2. Washington Ave 2222 E IBC 1017 MFD Position 7-7-2021.pdf

Date	Ver.	Action By	Action	Result
8/11/2021	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass