



Legislation Details (With Text)

File #: 66370 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 7/8/2021 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 8/11/2021
Enactment date: **Enactment #:**

Title: 30 Ash St
BLDVAR-2021-10505
Seeking a variance from 2015 IBC Table 504.4 limiting Type IIIB Group E buildings with sprinkler systems to a maximum of 3 stories above grade. The property owner is proposing an addition to extend elevator service to an existing fourth story above grade. Alder District 5.

Sponsors:

Indexes:

Code sections:

Attachments: 1. MMSD 5 - 30 Ash height.pdf, 2. Ash St 30 IBC 504 MFD Position 7-2-2021.pdf

Date	Ver.	Action By	Action	Result
8/11/2021	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

30 Ash St
BLDVAR-2021-10505
Seeking a variance from 2015 IBC Table 504.4 limiting Type IIIB Group E buildings with sprinkler systems to a maximum of 3 stories above grade. The property owner is proposing an addition to extend elevator service to an existing fourth story above grade. Alder District 5.