



Legislation Details (With Text)

File #:	68801	Version:	1	Name:	1919 Alliant Energy Way
Type:	Miscellaneous	Status:		Status:	Approved
File created:	12/9/2021	In control:		In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda:		Final action:		Final action:	12/21/2021
Enactment date:		Enactment #:			
Title:	<p>1919 Alliant Energy Way BLDVAR-2021-18908 Applicant is seeking a variance from IBC 3103.1.1 requiring that temporary structures conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code. IBC 903.2.1.3 Group A-3 requires an automatic sprinkler system where the fire area exceeds 12,000 square feet and has an occupant load of 300 or more. The applicant is proposing a temporary structure of 65,000 square feet to house the Trade Center of the World Dairy Expo.</p>				
Sponsors:					
Indexes:					
Code sections:					
Attachments:	1. 2022 TC CAD Drawing.pdf, 2. Application.pdf, 3. Floor Plan.pdf, 4. Map 28 - Outdoor Trade Mall.pdf, 5. Structural Calculations.pdf, 6. Trade Center Rendering.pdf, 7. IBC 903 & 907 MFD Position 12-13-2021.pdf				

Date	Ver.	Action By	Action	Result
12/21/2021	1		BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	

Title

1919 Alliant Energy Way
BLDVAR-2021-18908

Applicant is seeking a variance from IBC 3103.1.1 requiring that temporary structures conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code. IBC 903.2.1.3 Group A-3 requires an automatic sprinkler system where the fire area exceeds 12,000 square feet and has an occupant load of 300 or more. The applicant is proposing a temporary structure of 65,000 square feet to house the Trade Center of the World Dairy Expo.