



Legislation Details

File #: 68801 **Version:** 1 **Name:** 1919 Alliant Energy Way
Type: Miscellaneous **Status:** Approved
File created: 12/9/2021 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 12/21/2021
Enactment date: **Enactment #:**

Title: 1919 Alliant Energy Way
BLDVAR-2021-18908
Applicant is seeking a variance from IBC 3103.1.1 requiring that temporary structures conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code. IBC 903.2.1.3 Group A-3 requires an automatic sprinkler system where the fire area exceeds 12,000 square feet and has an occupant load of 300 or more. The applicant is proposing a temporary structure of 65,000 square feet to house the Trade Center of the World Dairy Expo.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2022 TC CAD Drawing.pdf, 2. Application.pdf, 3. Floor Plan.pdf, 4. Map 28 - Outdoor Trade Mall.pdf, 5. Structural Calculations.pdf, 6. Trade Center Rendering.pdf, 7. IBC 903 & 907 MFD Position 12-13-2021.pdf

Date	Ver.	Action By	Action	Result
12/21/2021	1		BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	