



## Legislation Details

---

**File #:** 69263      **Version:** 1      **Name:**  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 1/11/2022      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE  
CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 1/18/2022  
**Enactment date:**      **Enactment #:**

**Title:** 2222 E Washington  
BLDVAR-2021-19923  
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic  
sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo  
installing an automatic sprinkler system over the pool area within the building.  
Alder District 12.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 2021\_1216 MMSD East HS Signed Variance Application.pdf, 2. Washington Ave 2222 E IBC 903  
MFD Position 1-11-2022.pdf

Date	Ver.	Action By	Action	Result
1/18/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass