



## Legislation Details (With Text)

**File #:** 69264 **Version:** 1 **Name:**  
**Type:** Miscellaneous **Status:** Approved  
**File created:** 1/11/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE  
CODE AND LICENSING APPEALS BOARD  
**On agenda:** **Final action:** 1/18/2022  
**Enactment date:** **Enactment #:**

**Title:** 30 Ash St  
BLDVAR-2021-19926  
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.  
Alder District 5.

### Sponsors:

### Indexes:

### Code sections:

**Attachments:** 1. 2021\_1216 MMSD West HS Signed Variance Application.pdf, 2. Ash St 30 IBC 903 MFD Position 1-11-2022.pdf

Date	Ver.	Action By	Action	Result
1/18/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

### Title

30 Ash St  
BLDVAR-2021-19926  
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.  
Alder District 5.