



Legislation Details

File #: 69264 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 1/11/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE
CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 1/18/2022
Enactment date: **Enactment #:**

Title: 30 Ash St
BLDVAR-2021-19926
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic
sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo
installing an automatic sprinkler system over the pool area within the building.
Alder District 5.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2021_1216 MMSD West HS Signed Variance Application.pdf, 2. Ash St 30 IBC 903 MFD Position
1-11-2022.pdf

Date	Ver.	Action By	Action	Result
1/18/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	