



Legislation Details (With Text)

File #: 69265 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 1/11/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE
CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 1/18/2022
Enactment date: **Enactment #:**

Title: 702 Pflaum Rd
BLDVAR-2021-19924
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.
Alder District 15.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2021_1216 MMSD LaFollette Signed Variance Application.pdf, 2. Pflaum Rd 702 IBC 903 MFD
Position 1-11-2022.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|---|---------|--------|
| 1/18/2022 | 1 | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD | Approve | |

Title

702 Pflaum Rd
BLDVAR-2021-19924
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.
Alder District 15.