



## Legislation Details (With Text)

**File #:** 69266 **Version:** 1 **Name:**  
**Type:** Miscellaneous **Status:** Approved  
**File created:** 1/11/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE  
CODE AND LICENSING APPEALS BOARD  
**On agenda:** **Final action:** 1/18/2022  
**Enactment date:** **Enactment #:**

**Title:** 201 S Gammon  
BLDVAR-2021-19925  
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic  
sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo  
installing an automatic sprinkler system over the pool area within the building.  
Alder District 19.

### Sponsors:

### Indexes:

### Code sections:

**Attachments:** 1. 2021\_1216 MMSD Memorial HS Signed Variance Application.pdf, 2. Gammon Rd 201 S IBC 903  
MFD Position 1-11-2022.pdf

Date	Ver.	Action By	Action	Result
1/18/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

### Title

201 S Gammon  
BLDVAR-2021-19925  
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler  
system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic  
sprinkler system over the pool area within the building.  
Alder District 19.