



Legislation Details (With Text)

File #: 69780 **Version:** 1 **Name:**

Type: Miscellaneous **Status:** Filed

File created: 2/7/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

On agenda: **Final action:** 2/16/2022

Enactment date: **Enactment #:**

Title: 615 W Main #103
BLDVAR-2022-01158
Applicant is seeking a variance from 2015 IMC 402.3 where rooms or spaces without openings to the outdoors are ventilated through and adjoining room shall be unobstructed and shall have an area not less than 8% of the floor area of the interior room or space but not less than 25 sq ft. The owner is proposing a 110 sq ft interior room with two transfer grilles and an undercut door to allow ventilation. Alder District 4.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 615 W Main Photos.pdf, 2. 615 W Main #103.pdf, 3. FW Building Board Meeting.msg

Date	Ver.	Action By	Action	Result
2/16/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Deny	Pass

Title

615 W Main #103
BLDVAR-2022-01158
Applicant is seeking a variance from 2015 IMC 402.3 where rooms or spaces without openings to the outdoors are ventilated through and adjoining room shall be unobstructed and shall have an area not less than 8% of the floor area of the interior room or space but not less than 25 sq ft. The owner is proposing a 110 sq ft interior room with two transfer grilles and an undercut door to allow ventilation. Alder District 4.