



## Legislation Details

**File #:** 70255      **Version:** 1      **Name:**

**Type:** Miscellaneous      **Status:** Approved

**File created:** 2/24/2022      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

**On agenda:**      **Final action:** 3/24/2022

**Enactment date:**      **Enactment #:**

**Title:** 2 E Gilman  
BLDVAR-2022-02587  
The applicant is seeking a variance from the 2015 IBC 1024.5 requiring openings in exit passageways be limited to those necessary for exit access to the exit passageway from normally occupied spaces. Alder District 2.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 2 E Gilman app.pdf, 2. 2 E Gilman plan.pdf, 3. Gilman St 2 E IBC 402 MFD Position 2-21-2022.pdf

Date	Ver.	Action By	Action	Result
3/24/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	