



Legislation Details (With Text)

File #: 74249 **Version:** 1 **Name:** 420 State St
Type: Miscellaneous **Status:** Approved
File created: 10/13/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 11/1/2022
Enactment date: **Enactment #:**

Title: 420 State St
 BLDVAR-2022-14716
 The applicant is seeking a variance to SPS 321.04(4)(a) requiring an intermediate landing in be provided in any stairway with a height of 12 feet or more. The existing stairway is 13'-6" without an intermediate landing. Alder District #2

Sponsors:

Indexes:

Code sections:

Attachments: 1. 420 State app.pdf, 2. 420 State approved plans.pdf, 3. 420 State stair detail.pdf, 4. 420 State St slides.pdf

Date	Ver.	Action By	Action	Result
11/1/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

420 State St
 BLDVAR-2022-14716
 The applicant is seeking a variance to SPS 321.04(4)(a) requiring an intermediate landing in be provided in any stairway with a height of 12 feet or more. The existing stairway is 13'-6" without an intermediate landing. Alder District #2