



Legislation Details (With Text)

File #: 74250 **Version:** 1 **Name:** 609 Russell St
Type: Miscellaneous **Status:** Approved
File created: 10/13/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 11/1/2022
Enactment date: **Enactment #:**

Title: 609 Russell St
BLDVAR-2022-15179
The applicant is seeking a variance to SPS 321.06 requiring that hallways have a ceiling height of 7 feet. The proposed attic remodel would have a hallway ceiling that slopes 6'-4" at the lowest point. Alder District #6

Sponsors:

Indexes:

Code sections:

Attachments: 1. 609 Russell Framing.pdf, 2. 609 RUSSELL VARIANCE (1).pdf, 3. 609 Russell Variance App.pdf, 4. 609 Russell.pdf

Date	Ver.	Action By	Action	Result
11/1/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

609 Russell St
BLDVAR-2022-15179

The applicant is seeking a variance to SPS 321.06 requiring that hallways have a ceiling height of 7 feet. The proposed attic remodel would have a hallway ceiling that slopes 6'-4" at the lowest point. Alder District #6