



## Legislation Details

---

**File #:** 74250      **Version:** 1      **Name:** 609 Russell St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 10/13/2022      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 11/1/2022  
**Enactment date:**      **Enactment #:**

**Title:** 609 Russell St  
BLDVAR-2022-15179  
The applicant is seeking a variance to SPS 321.06 requiring that hallways have a ceiling height of 7 feet. The proposed attic remodel would have a hallway ceiling that slopes 6'-4" at the lowest point.  
Alder District #6

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 609 Russell Framing.pdf, 2. 609 RUSSELL VARIANCE (1).pdf, 3. 609 Russell Variance App.pdf, 4. 609 Russell.pdf

Date	Ver.	Action By	Action	Result
11/1/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass