



Legislation Details

File #: 74251 **Version:** 1 **Name:** 302 N Yellowstone Dr
Type: Miscellaneous **Status:** Denied
File created: 10/13/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 11/1/2022
Enactment date: **Enactment #:**
Title: 302 N Yellowstone Dr
BLDVAR-2022-15359
The applicant is seeking a variance to SPS 321.05(1) requiring that each habitable room be provided with natural light by means of glazed openings. The applicant would like to remove a window in an existing bedroom, reducing the natural light to less than 8% of the floor area. Alder District #19
Sponsors:
Indexes:
Code sections:
Attachments: 1. 302 N Yellowstone app.pdf, 2. 302 N Yellowstone plans.pdf

Date	Ver.	Action By	Action	Result
11/1/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Deny	Fail