



Legislation Details (With Text)

File #: 74488 **Version:** 1 **Name:** 1103 S Thompson Dr
Type: Miscellaneous **Status:** Filed
File created: 10/27/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 11/15/2022
Enactment date: **Enactment #:**
Title: 1103 S Thompson Dr
BLDVAR-2022-15975
The prospective property owner is seeking a variance to SPS 321.07(b) requiring exit doors be openable from the interior without the use of a key. The prospective property owner is proposing the installation of a magnetic locking system within the home to provide support for a resident with special health and safety needs and prohibit the resident from leaving without supervision. Alder District #16

Sponsors:

Indexes:

Code sections:

Attachments: 1. 1103 S Thompson application.pdf, 2. Thompson Dr 1103 S SPS 321 MFD Position 10-19-2022.pdf

Date	Ver.	Action By	Action	Result
11/15/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Deny	Fail
11/1/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Refer	Pass

Title

1103 S Thompson Dr
BLDVAR-2022-15975

The prospective property owner is seeking a variance to SPS 321.07(b) requiring exit doors be openable from the interior without the use of a key. The prospective property owner is proposing the installation of a magnetic locking system within the home to provide support for a resident with special health and safety needs and prohibit the resident from leaving without supervision. Alder District #16