



## Legislation Text

---

**File #:** 33755, **Version:** 1

---

### **Title**

2039 Winnebago Street (C-04-21-2014)

Mark Schmidt, Architect, appealing IBC 1208.2. The rule requires that the minimum ceiling height in a commercial space be 7' 6". The Variance requested is to allow 7' 0" in an existing building. The Madison Fire Department has no comment.