



Legislation Text

File #: 38045, **Version:** 1

Title

9414 Silicon Prairie Parkway (C-04-22-2015)

Kevin Burow of Knothe & Bruce Architects appealing IBC 1009.4.2, Riser Height. The Code allows stairways within the unit to be 7 3/4". The Variance requested is to allow poured in place concrete stairs to remain that have a rise of 7 1/4", that are exterior to the unit.