



Legislation Text

File #: 41765, **Version:** 1

Title

636 State Street (C-02-09-2016)

Jenny Dechant of Iconica appealing IBC 705.8.1. The rule does not allow openings on a property line. The variance requested is to allow an existing stairway at 610 State Street to lead to the basement at 638 State Street. A new two hour enclosure would be constructed. The Madison Fire Department supports the variance with conditions.