

Legislation Text

File #: 43750, Version: 1

Title

739 Williamson St (C-07-48-2016)

TJK Design appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.