



## Legislation Text

---

**File #:** 44491, **Version:** 1

---

### Title

3418 S Stone Creek Cir (C-09-59-2016)

Bouril Design appealing IBC 1208.2.1. The ruling requires the furred ceiling high to be 7'0". In addition the minimum door height shall be 80". The variance requested is to have a ceiling height in the basement of 6'7" and door heights of 76.5". The Madison Fire Department supports the variance with an extended smoke alarm system and a sprinkler system.