



Legislation Text

File #: 47296, **Version:** 1

Title

432 W Gorham St (C-05-29-2017)

Antunovich Associates appealing IBC 3007.4.4. The rule requires that the Fire Service Access Elevator Lobby be a minimum of 150 sq. ft. in area with a minimum dimension of 8'. The variance requested is to allow a lobby of 184 sq. ft. with dimensions of 7'2" x 25'9". The Madison Fire Department recommends approval. Aldermanic District 4