



Legislation Text

File #: 48016, **Version:** 1

Title

704 Williamson St (C-07-64-2017)

Joe Sinnett of Kahler Slater. The variance requested is to use Section 510.2 of the 2015 IBC Code to allow two stories below the grade plane. The Madison Fire Department supports the variance with conditions. 6th Alder District