



Legislation Text

File #: 48382, **Version:** 1

Title

4601 Frey St (C-08-72-2017)

Josh Wilcox of Gary Brink & Associates appealing IFC D105.2 Aerial Fire Apparatus Access Roads. The variance requested is to reduce the fire lane on Frey Street from 26' to 19'6" in width. The Madison Fire Department supports the variance. Alder District #11.