



## Legislation Text

---

**File #:** 50912, **Version:** 1

---

### Title

2537 Daniels St C-3-32-2018

Kenneth Berg of Specialized Electric appealing MGO 34.604. The rule requires that an on-site fuel supply be provided for the generator. The variance requested is to use a separate gas supply from MGE with separate valve to provide the second source. The Madison Fire Department is in the process of changing this ordinance.

Alder District 16