



Legislation Text

File #: 50916, **Version:** 1

Title

501 Charmany Dr C-3-34-2018

Robert Webber of Valerio Dewalt Train Associates appealing IBC 2009 Section 1005.1.

The rule establishes 0.3" per occupant in the stairways and 0.2" per occupant for other egress components.

The variance requested is to use the 2015 International Building Code in lieu of the 2009. The 2015 IBC will be used in its entirety. This project will use the 2009 Energy Conservation Code.

Madison Fire Dept. recommendation: Conditional Approval

Alder District 19