



Legislation Text

File #: 52837, **Version:** 1

Title

4101 Lien Rd C-08-66-2018

Roger Schregardus of Boldt Technical Services appealing IBC Table 506.2.

1-story building fully sprinklered system, IIB construction type F1 occupancy classification. Table 506.2 states maximum allowable area allowed is 62,000 sqft. The Madison Fire Department supports the variance to be 11% over allowable area.

Alder District 17