



## Legislation Text

---

**File #:** 54298, **Version:** 1

---

### Title

465 Science Dr.

BLDNCC-2018-10672

Kevin Seton of Affiliated Engineers is seeking an exception to local lighting control as required by Wisconsin Chapter SPS 363 in cGMP contractor development and manufacturing (CDMO) in a laboratory space. The specific section being petitioned is 9.4.1 (a) in ASHRAE 90.1 2013 for local control requirement in laboratory and corridor space types as defined in Table 9.6.1.

Alder District 10