

Legislation Text

File #: 54643, Version: 1

Title

4101 Lien Rd. BLDNCC-2018-14504 Roger Schregardus of Boldt Technical Services is seeking a variance to allow a 12" landing instead of the 44" landing as required under IBC 1010.1.6. The doors in question are Fire Department Access doors to high-piled storage per IFC 3206.6.1. The Fire Department Supports the variance. Alder District 17