



Legislation Text

File #: 55337, **Version:** 1

Title

1000 Edgewood College Dr.

BLDNCC-2013-06890

Michael Guns of Edgewood College is seeking a variance to request a special locking system for after hours for safety issues, such as an active shooter, appealing IBC 1010.1.9, which requires all exit doors to open from the egress side at all times. The City of Madison Fire Department has conditionally approved the variance.

Alder District #13