



Legislation Text

File #: 69265, **Version:** 1

Title

702 Pflaum Rd

BLDVAR-2021-19924

2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.

Alder District 15.